

**Circular No. (7)**

Reference: **TENDER 04/2016 –Construction of Road Nos. 1 & 5 and Drainage Systems at Duqm Port**

Tender Documents Collection date: 25 <sup>th</sup> April 16	Submission date: Tuesday/24 <sup>th</sup> May 2016
Site Visit: 10 <sup>th</sup> May 2016	<b><u>1<sup>st</sup> Revised Submission Date: Tue/21<sup>st</sup> June 2016</u></b>
	<b><u>2<sup>nd</sup> Revised Submission Date: Tue/12<sup>th</sup> July 2016</u></b>

**Subject: Reply to Queries**

Reference to the bidder's clarification on the above subject, kindly see attached reply to queries for your kind action and record.

**NOTES:**

- All Bidders are to endorse this Circular and attach it as part of their tender submission.
- Bidders are advised that SEZAD shall **not accept** any further queries as tender shall be submitted on: **Tuesday/ 12<sup>th</sup> July 2016 at 12.00, Muscat Time.**

Kind regards,

  
SEZAD, Tenders & Contracts



**Circular No. (7)**

**Reference: TENDER 04/2016 –Construction of Road Nos. 1 & 5 and Drainage Systems at Duqm Port**

**Query:**

Refer to Circular No. 6 issued on 28 June 2016 about the Tender Queries/Clarifications, Query No. 10.

- We presume that dimming control or centralized control system is not required for street lighting. If the same is required kindly provide BOQ items and electrical specifications."

**SEZAD reply:**

- Please ignore the Circular 6's response and follow the updated response as below:
- The dimming control or centralized control system is required as per the special specifications. The provision for the cost of system shall be included in the price of relevant BOQ items.



*[Handwritten signature]*